


TEST CERTIFICATE

Issued by
 Prysmian Cables & Systems – Wrexham Test Laboratory

Page 1 of 1 Date : 15/05/2008 Certificate No. PCL/T/668-B

Authorised By :



J.P. Rawlinson – Technical Manager MV , LV Accessories

Type Approval Tests to BS EN 50368:2003 - Cable Cleats for Electrical Installations

Product Range : 374LSF-- (2 Bolt LSOH, diam. range 50 – 94 mm)

Properties	Clause	Classification Achieved	Test Data
Cleat Type	6.1	6.1.2 Non-metallic	-
Impact Resistance	6.2	6.2.5 V.Heavy	Tested @ -40°C
Temp. for Permanent Application	6.4	-40°C to +60°C	-
Needle Flame Test	6.5. 10.0	Application time - seconds	>120
Lateral Load Test	9.2	Load applied – kN	1.22 -> 3.485
Axial Movement Test	9.5	Load applied – N	82 -> 110

Prysmian Cables & Systems Limited

Registered Office

Chickenhall Lane
 Eastleigh
 Hampshire
 SO50 6YU

Switchboard

T: 0870 5133 143
 T: 023 8029 5555